

The logo for IRSN, featuring the letters 'IRSN' in a bold, sans-serif font. The 'I', 'R', and 'S' are red, while the 'N' is blue.

INSTITUT
DE RADIOPROTECTION
ET DE SÛRETÉ NUCLÉAIRE

Reactivity insertions for the Borax accident in ORPHEE research reactor

September 2010, 1Xth / IGORR

Yacine Chegrani*, Florence Gupta, Franck Bernard
IRSN

Plan of the Presentation

■ Introduction

- Context
- Safety demonstration provided by the utility

■ IRSN assessment work on RIA

- Validation process of IRSN-made ORPHEE model
- Reactivity insertions evaluation
- Discussion



■ Conclusions

Context of the study


- **Second decennial safety review of French reactor ORPHEE**
 - Open core, pool type reactor built in 1986 by CEA
 - Neutron source reactor, 14MW
 - 8 square subassemblies, plate type fuel, aluminum clad, 93%
 - 9 neutron beam channels
 - 2 reflectors (Beryllium / heavy water)
 - 2 cold sources, 1 hot source in the reflector

IRSN is the technical support to French public authorities

- **Borax = severe reactivity insertion accident**
 - Safety goal: Robustness of the containment building and pool
 - Safety assessment procedure includes:
 - Reactivity worth of initiating events
 - Thermal consequences on fuel plates
 - Pressure load on the reactor structures



Layout of the core and subassemblies



Safety demonstration for ORPHEE regarding RIA

■ Two main identified initiating events


- Control fork excessive withdrawal → ramp insertion
 - No possible ejection (downward flow)
 - Transient protected by scram thresholds and feedback

■ Experimental equipment failure → instantaneous insertion

- Flooding of channels and probes by heavy water:
 - Less leakage in high flux area
- Disappearance of channels structure: sensitivity case
 - Less capture in high flux area

■ Evaluation of the consequences

- Reactor period
 - Higher than the experimental period for explosive borax (SPERT threshold at 4ms)
- Innovative best-estimated thermal-hydraulic simulation
 - Melting temperature of aluminum not reached



Instantaneous reactivity insertions

Equipment	Reactivity worth in \$
Flooding of Cold Source 1	0.21
Flooding of Cold Source 2	0.19
Vaporisation of H2 in Cold Source 1	0.17
Vaporisation of H2 in Cold Source 2	0.11
Flooding of Hot Source	0.20
Flooding of light pipes	0.12
Flooding of 9 channels	0.45
Total of flooding and vaporisation effects	1.46 (reference)
Structure disappearance of 9 channels	1.22
Total of flooding and structure effects	2.90 (sensitivity)

Safety demonstration analysis by IRSN

Equipment	Reactivity worth in \$
Flooding of Cold Source 1s	0.21
Flooding of Cold Source 2	0.19
Vaporisation of H2 in Cold Source 1	0.17
Vaporisation of H2 in Cold Source 2	0.11
Flooding of Hot Source	0.20
Flooding of light pipes	0.12
Flooding of 9 channels	0.45
Total of flooding and vaporisation effects	1.46 (reference)
Structure disappearance of 9 channels	1.22
Total of flooding and structure effects	2.90 (sensitivity)

- Lines in green have been measured during start-up
 - Enough confidence in these values
- Lines in red have only been calculated in 1974
 - Diffusion calculations with TRIDENT code
 - ➔ Worth making new calculations

Monte Carlo code MORET.5A1

- **Developed for criticality studies by IRSN**
 - Continuous energy cross sections
 - Geometrical model uses 3D basic closed shapes in networks
 - Single geometrical modules can be called several times in the geometry
 - Integration of an estimation of kinetic parameters

- **Validation procedure set up for this study**
 - Comparison between MORET5 calculations and available reference calculated data extracted from the safety report
 - several levels of geometry simplification
 - Comparison with identical model in MCNP

- **Kinetic parameters calculation**
 - Reliable experimental values, used as complementary indicator

Validation against the simplified model from design calculations

- Experimental equipment not simulated
- Two distributions of boron are applied

	No boron (MORET/MCNP/TRIDENT)	Homogeneous (MORET/MCNP/TRIDENT)
Control fork worth in \$	40 / 40 / 46	38 / 39 / 42
Critical Height in cm (exp = 58.6 cm)	27 / - / -	50 / 50 / 47
Bcalc/Bexp	0.9 / - / -	0.9 / - / 1
Lcalc/Lexp	1.8 / - / -	1.7 / - / 4.5

- Good general agreement

Validation against the available experimental data



- Heterogeneous distribution of boron, as it is during operation

	Heterogeneous (MORET)
Control fork worth in \$	37
Critical Height in cm (exp = 58.6 cm)	58
B_{calc}/B_{exp}	0.9
L_{calc}/L_{exp}	1.8

- Better agreement
- Addition of experimental equipment improves L calculations
 - Dependent on the quantity of heavy water in high flux areas

Calculations of reactivity insertions

- Addition of 9 neutron beam channels
 - Equivalent volume at mid-plan
 - Precise description of each channel



	Reactivity in \$ (Ring - IRSN)	Reactivity in \$ (CEA 80's)	Reactivity in \$ (Precise - IRSN)
Flooding	2.2	0.5	2.1
Structure	0.4	1.22	0.7

Discussions

- **CEA provided new results obtained with TRIPOLI 4 (Monte Carlo)**
 - Validation against the measured cold source worth
 - 9 Channels reactivity worth evaluation (precise description)

	Reactivity in \$ (CEA)	Reactivity in \$ (IRSN)
Flooding	1.7	2.1
Structure	1.6	0.7

- **Discrepancies have been addressed**
 - Flooding: difference in heavy water reflector purity
 - Structure: difference in aluminum thickness

Conclusions

Equipment	Safety report calculations (80's)	Up-to-date calculations
Flooding of Cold Source 1	0.21	0.25
Flooding of Cold Source 2	0.19	0.15
Vaporisation of H2 in Cold Source 1	0.17	0.12
Vaporisation of H2 in Cold Source 2	0.11	0.11
Flooding of 9 channels	0.45	1.65
Total of flooding and vaporisation effects	1.46	2.66
Structure disappearance of 9 channels	1.22	1.62
Total of flooding and structure effects	2.9	4.3

- **These new values pull the reactor period closer to the experimental threshold**
- **Safety report values will be updated**
 - 2.9 \$ will become the reference case, and no sensitivity case will be considered
- **Periodic examinations and replacement schedule of the neutron beams will be modified and tightened to reduce the risk of simultaneous failure**

The logo for IRSN, featuring the letters 'IRSN' in a bold, sans-serif font. The 'I' and 'R' are red, while the 'S' and 'N' are blue.

INSTITUT
DE RADIOPROTECTION
ET DE SÛRETÉ NUCLÉAIRE

Thank you for your
attention