



# **Safety Enhancement of Dhruva Reactor through Periodic Safety Review(PSR)**

**Pankaj P. Bhuse**

**Senior Shift Engineer**

**Dhruva Research Reactor**

**Reactor Group**

**Bhabha Atomic Research Centre**

**Trombay– Mumbai (Maharashtra)**

**India-400094**




# Outline of presentation

- About BARC
- About Dhruva
- About PSR and its methodology
- Safety factors review ,outcome – safety upgrades
- Conclusion



# Bhabha Atomic Research Centre




**A Multi-disciplinary, Multi-scale R & D Organization. Located at Trombay with sister units located at Tarapur, Kalpakkam, Mysore, Srinagar & Gulmarg, Mt. Abu, Gauribidanur, ESLs and Seismic Stations at various places in the country**

- **RESEARCH REACTORS**
- **REPROCESSING PLANT**
- **WASTE MANAGEMENT FACILITIES**
- **FUEL FABRICATION**
- **IRRADIATION FACILITIES**
- **OTHER R & D LABS**

# Research Reactors at Trombay

- Apsara – 1 MWt, Pool Type, First Criticality in 1956, under up-gradation to 2 MW
- Cirus – 40 MWt, Tank Type, Critical in 1960, Permanent Status :S/D from Dec-2010
- Dhruva – 100 MWt, Tank Type, Critical in 1985 – In Operation
- 100 W AHWR Critical Facility
- More than 125 reactor- years of O & M experience with good safety record.



**APSARA (1956) – The Epitome of Initiation of Indian Nuclear Programme. The Reactor was decommissioned . Construction of 2 MW upgraded APSARA in progress.**



**Dhruva & Cirus Reactor at BARC. (Cirrus was Shutdown in 2010)**



# About Dhruva

First Criticality	: August 8, 1985
Rated Power	: 100 MW <sup>th</sup>
Peak thermal Flux	: <b>1.8 X 10<sup>14</sup> n/cm<sup>2</sup>-sec</b>
Orientation	: Vertical Tank Type
Fuel	: Natural uranium metal
Coolant	: Heavy water
Moderator/ Reflector	: Heavy water
Reactor Regulation	: <b>Level control of moderator</b>
Primary Shutdown	: <b>Cadmium Shut off rods (9)</b>



# Panoramic view of Dhruva





# Periodic Safety Review (PSR)

- Periodic Safety Review is an important regulatory instrument for maintaining and improving safety throughout the operating life cycle of the nuclear reactor
- These safety reviews are of two types
  - ❑ A limited scope safety review for **Renewal of Authorisation (RA)** conducted every five years and
  - ❑ A very comprehensive full scope review called **Periodic Safety Review (PSR)** conducted every ten years



# PSR for RAO

## (Renewal of Authorization for Operation)

- Earlier RAO for operation of the Research Reactor was based on safety reviews and regulatory inspections by regulatory body.
- **As regulatory requirement;** PSR was made mandatory for RAO.
- Full scope PSR of Dhruva reactor was conducted for renewal of authorization for operation in year 2014 and reactor got authorization upto 2019
- The PSR has been helpful in identifying weaknesses in system configuration and implementing a few safety upgrades of Dhruva





# PSR for RAO


## (Renewal of Authorization for Operation)


- Guidelines for PSR
- Reference documents
  - ❑ **Safety manual no. BSCS/SM/2010/1 Edition;R-0, March-2010**
  - ❑ **AERB safety guide no. AERB/SG/O-12**
  - ❑ **IAEA safety Standards Series No SSG-25**
  - ❑ **IAEA NSR-4**



# Regulatory framework in BARC









# PSR: Starting point and End point

➤ **Starting point** : Agreement between Regulatory Body and Facility Management

- **Scope of PSR**
- **Objective**
- **Time schedule**
- **Expected outcome from PSR**

➤ **End point** : Approval by regulatory body for safety improvements / corrective actions



# Scope of PSR

- Adherence to technical specifications for operations
- Review of annual plant performance reports
- Review of anomaly reports , ERs and SERs
- Radioactive releases to the environment
- Radiation exposures
- System and procedural modifications
- Industrial safety
- Safety committee recommendations and compliance
- Reports of internal regulatory inspections
- Reports of external regulatory inspections and compliance for their recommendations



# Scope of PSR

- Dhruva PSR took into account
  - **Cumulative effects of plant aging as Dhruva has completed more than 30 yrs. of operation**
  - **Modification carried out over the years**
  - **Feedback of operating experience**
  
- Review of all applicable safety factors based on guidelines
  
- Global assessment based on safety factors review



# Objective and expected outcome

- PSR is intended to identify the strengths and shortcomings of the reactor against the requirements of **current standards/practices**
- PSR is used to identify the **modifications or upgrades** required to compensate for any safety significant shortcomings
- Review of documents of operational safety aspects will provide necessary inputs for **concluding on overall safety culture of plant**





# Objective & expected outcome

- PSR is intended to be utilised for **reauthorisation of Dhruva**
- PSR will address issues related to **residual life of SSCs , aging studies** to be conducted & **refurbishment requirement**
- The report on the PSR is subjected to regulatory review in multi-tier review process for satisfactory resolution of the shortcomings



# Safety factors

**SF#1: Design**

**SF#2 : Actual condition of SSCs**

**SF#3 : Equipment qualification**

**SF#4 : Ageing**

**SF#5 : Hazard analysis**

**SF#6 : Deterministic analysis and PSA**

**SF#7 : Safety performance**

**SF#8 : Radiological protection**

**SF#9 : Operational feedback of other plants**

**SF#10 : Organization & Administration**

**SF#11 : Human factors**

**SF#12 : Procedures**

**SF#13 : Emergency planning**

**SF#14 : Radiological impact on environment**



# Safety factor #Design

- Comparison of plant design with current standard: **IAEA NS-R-4**
  - ❑ Dhruva Seismic design  
Seismic Coefficient Method
  - ❑ Seismic requalification based on Review Basis Ground Motion in progress most of the system have qualified.
  - ❑ Checking of safety margins.
- Plant performance factors-10 years
- Modifications in the plant system design

# Supplementary Control panel (SCP)

- It is back up to Main Control Room. (MCR) and will carry out all safety functions like **shutdown of reactor, ensuring core cooling / containment** during inhabitability of MCR like fire and damage to MCR
- It is physically isolated from MCR. It is in different fire zone.





# Safety factor # Equipment qualification

- List of Systems covered under qualification programme
  - Primary Shutdown systems
  - Back up shutdown systems
  - ECCS
  - Emergency Cooling system
  - Control and instrumentation
- Methodology of qualification under DBA (LOCA)
  - Temperature rise is nominal
  - only Relative Humidity is of concern.
  - Pressure rise is nominal




# Safety factor # Ageing

- In Service Inspection programme
- Ageing Mechanisms : Obsolescence, Corrosion, fluence
- Identification of age related degradation
  - PM programme
  - Condition Monitoring
  - Calibration/ testing
  - Surveillance
  - Chemical Control
- The effectiveness of operational and maintenance programme in managing ageing of replaceable components
- Various systems have been refurbished
- NDT of Dhruva Civil structure and AMP

# Reactor Trip Logic System

Up-gradation of Reactor Trip Logic System(RTLS) of Dhruva was taken up ( based on TPLC-32 platform)

- It was facing obsolescence
- It had limited diagnostic features.



# Secondary heat Exchangers

Heat exchangers were replaced

- Significant tube thinning
- Tube leakages
- Sea water ingress into DM water





# Replacement of Main DG sets

Replacement of all diesel generators sets ( 500 KVA)

- To combat technical obsolescence
- Also to avoid common cause failure .





# Safety factor # Hazard analysis

## Internal hazards:

- Fire : Plant preparedness , Fire EOP, Fire Drill
- Internal flooding : EOP , pumping provision, clamping provision
- Internal Missile Attack: due to detachment of Main coolant pump flywheel-cooling ensured



## External hazards

- ❑ Flooding due to heavy rains : **Plant preparedness-pre-monsoon checks, deployment of submersible pumps and drainage system designed for 204 mm/ hr of precipitation.**
- ❑ Seismic hazard : **Seismic requalification of SSCs (for checking safety margins for beyond DBE , Installation of seismic instrumentation and incorporation of seismic trip in Dhruva ( Trip value will be 80% of OBE),**
- ❑ Flooding due to Tsunami and storm surge : **Plant preparedness is adequate for DBFL. But for BDBFL some preparations are on hand**

# Engine Driven Pumps (EDPs)

➤ EDP: Station  
Black Out (SBO)



- BDB flood proof pump house to ensure core cooling
- Air cooler DG sets at higher elevation in view of BDBFL
- Hook up points
- Fire hydrant to SFSB



# Safety factor# Deterministic safety analysis and PSA


## ➤ Deterministic safety analysis

- LOOP :Flow coast down analysis
- Compressed air failure
- LOCA : Dose to public is well within the limit
- LORA
- And other PIEs

## ➤ Probabilistic Safety Assessment (PSA)

- PSA level-1: CDF (  $4.8 * 10^{-5}$  /year)
- PSA level-2: containment event tree event likelihood (  $3.4 * 10^{-6}$  / year)
- Reliability analysis of ECCS**  
**Unavailability decreased**

# ECCS modification



DHRUVA: EMERGENCY CORE COOLING SYSTEM



# Safety factor# radiological protection

- Plant dose normal
- Modification in SFSB purification system
- Plant dose consumption reduced



# Safety factor# Human factor

- Plant have adequate qualified staff at all the time
- Licensing procedure , training, refresher training
- Relicensing : After long leave ( 35 days)
- Man-machine Interface
- Dhruva Simulator to enhance operator confidence







# Conclusion

- Based on review as discussed earlier, the plant preparedness and capabilities to perform safe operations within LCOs and actual condition important to safety; **it is concluded that the Plant was operated safely.**
- In view of safety culture adopted by plant ; **plant can be operated safely for coming years without any risk** to members of public , plant personnel and plant

# Thank you for attention

