

## **United States Department of Commerce** Technology Administration National Institute of Standards and Technology

NISTIR 5026

235

Thermal Hydraulic Tests of a Liquid Hydrogen Cold Neutron Source

J.D. Siegwarth D.A. Olson M.A. Lewis J.M. Rowe R.E. Williams P. Kopetka





Figure 1. Design of the liquid hydrogen containing neutron moderator chamber for the NBSR.



Drawing of the NIST-B electrically heated glass moderator chamber used to test the NBSR chamber. Figure 4.




Figure 3. Unscaled diagram of the moderator test system built at NIST-B.

238

+






Figure 7. Test 4 showing the balance reading as a function of time at the power levels shown and 85 kPa pressure.

239



240

TOTAL P.02



## **Results of Boulder Tests**

- 1. Stable operation possible up to at least 2200 watts with two-phase flow.
- 2.  $LH_2$  mass quickly reaches new, stable value after heat load change.
- 3. Void fraction well below 20 % at anticipated power and pressure.
- 4. Restart of  $LH_2$  flow verified after extending supply line.
- 5. Visual inspection showed no dryout or unexpected voids.