

## Safety Analysis For Prototype MNSR HEU Core Unloading And Storage

#### Lu Jin, Wu Xiaobo, Peng Dan, Hong Jingyan, Li Yiguo

18<sup>th</sup> IGORR Conference 2017

China Institute of Atomic Energy

2018/3/2



#### Contents

Introduction
 Procedure
 Critical safety
 Radiation safety
 Conclusion






Miniature Neutron Souce Reactor (MNSR)

Prototype MNSR is a 27-kW research reactor and can supply 1 × 10<sup>12</sup> n·cm<sup>-2</sup>s<sup>-1.</sup>

type:tank-poolmoderator :light waterfull power operation:1984shutdown :2014conversion:2015from HEU to LEU







1 control rod : Cd
 1 fuel assembly: 376 fuel pins,
 35 depleted U pins, 5 tie rods.
 reflectors: upper Be, side Be
 and lower Be.

with 5 inner irradation tubes 5 outer irradation tubes. 1 experiment tubes




















1 )Put 5 Cd strings into 5 inner irradiation tubes respectively (one Cd string consists 3 Cd absorbers); put 1 Cd tube into experiment tube;


- 2) remove the control rod;
- 3) remove the upper beryllium reflector;
- 4) remove HEU fuel assembly from the reactor vessel;






# 5)Put HEU fuel assembly into a temporary cask; 6)trasnform the HEU fuel from the cask to the swimming-pool reactor for

storage.




Cd strings and Cd tube for ensure the reactor remain subcritical.





#### **1.Initial status**






2.reacitivity changes before unloading HEU fuel assembly (experimantal result)

Operation	<b>Reactivity/mk</b>	State of reactor
Initial status	-3.10	subcritical
Put 5 cadmium strings	-15.46	subcritical
Put 1 Cadmium tube	-15.79	subcritical
remove control rod	-8.79	subcritical
remove upper beryllium reflector	-18.83	subcritical



3.reacitivity changes before unloading HEU fuel assembly





3.reacitivity changes before unloading HEU fuel assembly (MCNP code calculation)

position /cm	K <sub>eff</sub>	reactor	remarks
0	0.979	subcritical	at the bottom
5	0.970	subcritical	5 cm from bottom
10	0.943	subcritical	10 cm from bottom
15	0.915	subcritical	15 cm from bottom
20	0.892	subcritical	20 cm from bottom
25	0.878	subcritical	25 cm from bottom
125	0.874	subcritical 125 cm from bottom far away from reflect	
625	0. 515	subcritical	625 cm from bottom in the air, no moderator





4.Accident analysis Fuel assembly falls into the pool and forms new geometry arrangement. 0.90 0.87 keff best lattice is 1.3 cm and keff=0.9086 0.84 0.81 1.2 1.5 1.8 0.9 lattice(cm)





**Results:** 

1. During the whole unloading procedure, the reactor remains subcritical.

2. Even in the worst accident, the keff is far away 1.

3. HEU fuel assembly will not return critical without the reflectors and moderator.



1. Reactor Core Source Term Calculation


Prototype MNSR totally run in term of 7258 hours in full power. The integrated power is  $1.95 \times 10^{5}$ kWh and integrated neutron fluence is  $2.61 \times 10^{19}$ n/cm2. Until March 2015, the reactor has been shutdown for 12 months and ready for unloading.

The source term is obtained by ORIGEN 2 code. The total reacitivity is  $5.22 \times 10^{12}$  Bq 12 months after shutdown and  $\gamma$  activity is  $3.74 \times 10^{12}$  Bq. Radioactive activity of actinide is  $1.34 \times 109$  Bq and neutron source intensity of spent fuel assembly is 1.69 Bq.

## **Radiaiton** safety



2. Temporary cask











3. lead thickness and  $\gamma$  dose rate calculation

Lead thickness /cm	distance to surface /cm	dose rate /mSv/h	Lead thickness /cm	distance to surface /cm	dose rate /mSv/h
9	0	4.07E+00	10	2	2.68E-02
9	1	1.58E-01	11	0	1.16E+00
9	2	4.81E-02	11	1	5.04E-02
10	0	2.09E+00	11	2	1.53E-02
10	1	8.91E-02			





3.  $\boldsymbol{\gamma}$  dose rate of temporary cask under water without 2 covers

position	dose rate /mSv/h
side surface	6.27×10 <sup>-2</sup>
1m from side surface	6.56×10 <sup>-3</sup>
top of water	3.62×10 <sup>-1</sup>
1m from top water	5.30×10 <sup>-2</sup>









# Radiaiton safety











#### **Results:**

- 1.The calculation of the source term is conservative.2.The temporary cask designed and fabricated is safe enough for protection.
- 3.During the unloading and storage , the  $\gamma$  dose of staff meet the requirement( < 100  $\mu$ Sv/day).





The HEU fuel assembly is unloading from MSNR reactor vessel and stored in swimming pool reactor safely.

The HEU fuel assembly remains subcritical during unloading and storage.



The unloading and storage of HEU fuel has little impact on the enviroment and staff.



Important data and experience for other HEU MNSR users to unloading and storage.



# Thanks for your

# attention and

questions!

panluj<mark>in@si</mark>na.com

United states of the second se

Prove Jet mal-colonianit,

Statute of the local division in the local division of the local d

in uoileit